

Certificate of Compliance – VOC Emissions

FLAME CURB Type X PG-11 #5/8" FCX (Gypsum Board) PABCO Gypsum

PABCO Gypsum selected a sample representative of its FLAME CURB Type X PG-11 #5/8" FCX product manufactured in Las Vegas, NV and submitted it for testing on June 14, 2010. Berkeley Analytical measured and evaluated the emissions of volatile organic compounds (VOCs) from this sample according to California Department of Health Services (CDHS) *Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers* (CA/DHS/EHLB/R-174, 2004, including 2004 Addenda; *also known as*, chamber testing portion of CA Section 01350) and ASTM Standard Guide D 5116-06. Chemical sampling and analysis were performed following U.S. EPA Compendium Methods TO-1 and TO-17 and ASTM Standard Method D 5197-09.

Calculations were performed with the following classroom and office exposure parameters to project the concentrations of VOCs of concern resulting from the use of the product. These parameters are taken from California Department of Public Health CDPH/EHLB/Standard Method V1.1, 2010. The results of the test and the calculated concentrations for the classroom and office are presented in Berkeley Analytical laboratory report, 418-002-01A-Jul1910.

Exposure Scenarios

Standardized Environment	Room Volume (m ³)	Area Specific Air Flow Rate (m/h)	Wall Area (m ²)
Classroom	231	2.02	94.6
Office	30.6	0.62	33.4


Summary of test results according to the CA DHS Standard Practice guidelines:

- Predicted concentrations of all VOCs of concern including formaldehyde were below the guideline concentrations.


Based on these results, the tested product sample meets the VOC emission requirements for use in classroom and office environments as defined in the CA DHS *Standard Practice*. Thus, the testing requirements are met to qualify the product as a low-emitting material in the Collaborative for High Performance Schools rating system (CHPS Designed & CHPS Verified).

Certificate No.: 100719-01

Dated: July 19, 2010



Raja S. Tannous
Laboratory Director



Kelly M. Campbell
Quality Manager

FC08.1